

Boiler PTE Evaluation Template

Equipment: One 60 MMBtu/hr natural gas boiler with #2 fuel oil backup and
One 10 MMBtu/hr Boiler fired by natural gas only.

Assumptions:

AP-42, section 1.4 and 1.3 AP-42 is the standard default, specific source test results are preferable.

Pollutant	Natural Gas Emission Factors (lb/mmcf)	Emission Factor Rating	Fuel Oil Emission Factors (lb/1000 gal)	Emission Factor Rating
NO _x	100	B	20	A
CO	84	B	5	A
PM	7.6	D	2	E
PM ₁₀	7.6	D	1	E
SO ₂	0.6	A	142S, where S = 0.5	A
VOC	5.5	C	0.34	A
Lead	0.0005	D	9 lb/10 ¹² Btu	C
Single HAP Hexane Formaldehyde	1.8 .0750	E E	NA .033	NA C
Total HAP	1.89		0.041 lb/1000 gal for the non-metals 49 lb/10 ¹² btu for metals (0.0068 lb/1000gal) 0.048 lb/1000gal total HAPs	

Calculations:

PTE for NO_x:

Boiler (60 MMBtu/hr):

Natural gas:

$$[(60 \text{ MMBtu/hr}) / (1020 \text{ MMBtu/mmcf})] (100 \text{ lb/mmcf}) (8760 \text{ hr/yr}) / (2000 \text{ lb/ton}) = 25.76 \text{ tpy NO}_x$$

Fuel Oil:

$$[(60 \text{ MMBtu/hr}) / (140 \text{ MMBtu/1000 gal})] (20 \text{ lb/1000 gal}) (8760 \text{ hr/yr}) / (2000 \text{ lb/ton}) = 37.54 \text{ tpy NO}_x \leftarrow \text{Worst Case}$$

Boiler (10 MMBtu/hr):

Natural Gas:

$$[(10 \text{ MMBtu/hr}) / (1020 \text{ MMBtu/mmcf})] (100 \text{ lb/mmcf}) (8760 \text{ hr/yr}) / (2000 \text{ lb/ton}) = 4.29$$

tpy

Total NO_x = 37.54 tpy + 4.29 tpy = 41.83 tpy

PTE for CO:

Boiler(60MMBtu/hr):

Natural Gas:[(60 MMBtu/hr)/(1020 MMBtu/mmcf)](84 lb/mmcf)(8760 hr/yr)/(2000 lb/ton) = 21.64 tpy CO <— Worst Case

Fuel Oil:[(60 MMBtu/hr)/(140 MMBtu/1000 gal)](5 lb/1000 gal)(8760 hr/yr)/(2000 lb/ton) = 9.38 tpy CO

Boiler (10 MMBtu/hr):

Natural Gas:[(10 MMBtu/hr)/(1020 MMBtu/mmcf)](84 lb/mmcf)(8760 hr/yr)/(2000 lb/ton) = 3.61 tpy CO

Total CO= 21.64tpy CO + 3.61tpy CO = 25.25tpy CO

PTE for PM:

Boiler(60MMBtu/hr):

Natural Gas:[(60 MMBtu/hr)/(1020 MMBtu/mmcf)](7.6 lb/mmcf)(8760 hr/yr)/(2000 lb/ton) = 1.96 tpy PM

Fuel Oil:[(60 MMBtu/hr)/(140 MMBtu/1000 gal)](2 lb/1000 gal)(8760 hr/yr)/(2000 lb/ton) = 3.75 tpy PM <— Worst Case

Boiler (10 MMBtu/hr):

Natural Gas:[(10 MMBtu/hr)/(1020 MMBtu/mmcf)](7.6 lb/mmcf)(8760 hr/yr)/(2000 lb/ton) = 0.33 tpy PM

Total PM= 3.75 tpy PM + 0.33 tpy PM = 4.08 tpy

PTE for PM₁₀:

Boiler(60MMBtu/hr):

Natural Gas:[(60 MMBtu/hr)/(1020 MMBtu/mmcf)](7.6 lb/mmcf)(8760 hr/yr)/(2000 lb/ton) = 1.96 tpy PM₁₀ <— Worst Case

Fuel Oil:[(60MMBtu/hr)/(140 MMBtu/1000 gal)](1 lb/1000 gal)(8760 hr/yr)/(2000 lb/ton)=1.88 tpy PM₁₀

Boiler (10 MMBtu/hr):

Natural Gas:[(10 MMBtu/hr)/(1020 MMBtu/mmcf)](7.6 lb/mmcf)(8760 hr/yr)/(2000 lb/ton) = 0.33 tpy PM₁₀

Total PM₁₀= 1.96 tpy PM₁₀ + 0.33 tpy PM₁₀ = 2.29 tpy

(Assuming all PM is PM₁₀ for natural gas.)

PTE for SO₂:

Boiler(60MMBtu/hr):

Natural Gas:[(60MMBtu/hr)/(1020 MMBtu/mmcf)](0.6 lb/mmcf)(8760 hr/yr)/(2000 lb/ton) = 0.15 tpy SO₂

Fuel Oil:[(60 MMBtu/hr)/(140 MMBtu/1000 gal)](71 lb/1000 gal)(8760 hr/yr)/(2000 lb/ton) = 133.3 tpy SO₂<— Worst Case

Boiler (10 MMBtu/hr):

Natural Gas:[(10MMBtu/hr)/(1020 MMBtu/mmcf)](0.6 lb/mmcf)(8760 hr/yr)/(2000 lb/ton) = 0.03tpy SO₂

Total SO₂= 133.3tpy SO₂ + 0.03 tpy SO₂ = 133.33 tpy

PTE for VOC:

Boiler(60MMBtu/hr):

Natural Gas:[(60MMBtu/hr)/(1020 MMBtu/mmcf)](5.5 lb/mmcf)(8760 hr/yr)/(2000 lb/ton) = 1.42 tpy VOC <— Worst Case

Fuel Oil:[(60 MMBtu/hr)/(140 MMBtu/1000 gal)](0.34 lb/1000 gal)(8760 hr/yr)/(2000 lb/ton) = 0.64 tpy VOC

Boiler (10 MMBtu/hr):

Natural Gas:[(10MMBtu/hr)/(1020 MMBtu/mmcf)](5.5 lb/mmcf)(8760 hr/yr)/(2000 lb/ton) = 0.24tpy VOC

Total VOC= 1.42 tpy VOC + 0.24 tpy VOC = **1.66 tpy**

PTE for Lead:

Boiler(60MMBtu/hr):

Natural Gas:[(60MMBtu/hr)/(1020 MMBtu/mmcf)](0.0005 lb/mmcf)(8760 hr/yr)/(2000 lb/ton) = 0.00013 tpy Lead

Fuel Oil:[(60 MMBtu/hr)(9 lb/10¹² Btu)](8760 hr/yr)/(2000 lb/ton) = 0.0024 tpy Lead <— Worst Case

Boiler (10 MMBtu/hr):

Natural Gas:[(10MMBtu/hr)/(1020 MMBtu/mmcf)](0.0005lb/mmcf)(8760 hr/yr)/(2000 lb/ton) = 2.15*10⁻⁵ tpy Lead

Total Lead= 0.0024 tpy Lead + 2.15*10⁻⁵ tpy Lead = **0.00242 tpy**

PTE for Single HAP (Hexane):

Boiler(60MMBtu/hr):

Natural Gas(Hexane):[(60MMBtu/hr)/(1020 MMBtu/mmcf)](1.8 lb/mmcf)(8760 hr/yr)/(2000 lb/ton) = 0.46tpy Hexane

Boiler (10 MMBtu/hr):

Natural Gas(Hexane):[(10MMBtu/hr)/(1020 MMBtu/mmcf)](1.8 lb/mmcf)(8760 hr/yr)/(2000 lb/ton) = 0.08 tpy Hexane

Total Single HAP= 0.46 tpy Hexane + 0.08 tpy Hexane = **0.54 tpy** <— Worst Case Single HAP

PTE for Single HAP (Formaldehyde):

Boiler(60MMBtu/hr):

Natural Gas(Formaldehyde):[(60MMBtu/hr)/(1020 MMBtu/mmcf)](0.075 lb/mmcf)(8760 hr/yr)/(2000 lb/ton) = 0.02tpy Formaldehyde

Fuel Oil (Formaldehyde):[(60 MMBtu/hr)/(140 MMBtu/1000 gal)](0.033 lb/1000 gal)(8760 hr/yr)/(2000 lb/ton) = 0.062 tpy Formaldehyde <— Worst Case

Boiler (10 MMBtu/hr):

Natural Gas(Formaldehyde):[(10MMBtu/hr)/(1020 MMBtu/mmcf)](0.075lb/mmcf)(8760 hr/yr)/(2000 lb/ton) = 0.003tpy Formaldehyde

Total Single HAP= 0.062 tpy Formaldehyde + 0.003 tpy Formaldehyde = 0.065 tpy

PTE for Total HAP:

Boiler(60MMBtu/hr):

Natural Gas:[(60MMBtu/hr)/(1020 MMBtu/mmcf)](1.9 lb/mmcf)(8760 hr/yr)/(2000 lb/ton) =0.49 tpy Total HAP ← Worst Case

Fuel Oil:[(60 MMBtu/hr)/(140 MMBtu/1000 gal)](0.048 lb Total HAP/1000 gal)(8760 hr/yr)/(2000 lb/ton) =0.090 tpy Total HAP

Boiler (10 MMBtu/hr):

Natural Gas:[(10MMBtu/hr)/(1020 MMBtu/mmcf)](1.9 lb/mmcf)(8760 hr/yr)/(2000 lb/ton) = 0.08 tpy Total HAP

Total Total HAP= 0.49 tpy Total HAP + 0.08 tpy Total HAP= 0.57 tpy